

Highways Annex A - dated 29 April 2025.

Issue	Date Reported	By Whom	To	Progress
Parish Steward Visits 2025 Usually, on a Thursday in month.	Next Visits 2025 Nil visit May. 25 June.			Any issues to be reported to KW for Parish Steward's next visit.
West Tockenham, Flooding. C120 Main Village	April 23	DK	WC	Blocking gully investigations at Field view indicates a link to main Village flooding issues. Work carried out 21 st Nov 24 however main Village flooded after this during 'Storm Bert' Nov 24.
Tockenham Wick, Flooding <i>Update from site visit 9th Oct 2024 with David Arnup (DA) and Martin Cook (MC).</i> 21 st Nov Chase email to MC – Reply, MC chasing Drainage Team for meeting.	April 23	KW	WC	KW had a further site meeting with DA and MC 9 th Oct 2024. Investigations to proceed looking at alternative measures to reduce flood risk. Action DA and MC.
Tockenham Corner / Primrose Hill - Flooding Request for review of findings following WC Drainage Team site visit July 2024.	Nov 2024	KW	WC AB	Wiltshire Councillor (AB) assured of site visit after 6 May 2025. Date TBC
Potholes Mermaid Corner C120 junction with Preston Lane Case No 00213815.	Feb 2025	KW	WC	Works carried out 13 Feb 25. Not completed – New Potholes developed since.
Opposite Field View - No 1 Tockenham. Blocked drain/gully. Road area by sewage plant now breaking up due to constant flow of water. Issue linked to main Village flooding. SEE ABOVE	Sept 23	KW	WC	Case No.00125935. Investigation Aug 24 shows fractured pipe. Works due Oct 24. Works carried out 21 st Nov 24.
Flooding – south of Rowley Copse.	Nov 24	KW	WC	Culvert blasted. Awaiting possible watercourse re-direction work by landowner east side of culvert. NOTE – Concerns exist that this may impact on Tockenham Corner. Awaiting advice from WC Drainage Team.
Junction with Preston Lane C130. – Mermaid Corner. Continuous flooding. <i>Update – Nov 24 KW chase email to MC/DA to hasten works request.</i>	Nov 23	KW	WC	Case number is 0013210. Requires extensive surveys. Following site meeting with KW and AB, drainage and highways teams to work together to investigate.
Pothole case No.- Greenway 148264 Orchard Lane – 148105 and 148101 Greenway 144238.	Jan 24	KW	My Wilts App	Reported. Awaiting repair/investigation. Ongoing as C class road – low priority.
Case 6487 - A3102 Tockenham Corner Junction Flooding at Culvert.	Jan 24	KW	My Wilts App	Case closed Apr 2025.